



# The Regional Municipality of Halton

[www.halton.ca](http://www.halton.ca)

## SOUTH HALTON WATER AND WASTEWATER MASTER PLAN UPDATE CLASS ENVIRONMENTAL ASSESSMENT STUDY NOTICE OF COMPLETION

### STUDY

Halton Region has completed the South Halton Water and Wastewater Master Plan Update. The purpose of a Master Plan is to provide a comprehensive look at future community needs. In 2002, a comprehensive master servicing strategy (Halton Water and Wastewater Master Plan Review, 2002) was prepared to address the Region's water and wastewater servicing needs within the 2016 planning horizon. This update identifies a preferred servicing strategy to accommodate growth to the year 2021. This study reviewed the recommendations of the previous study in the context of the current regulatory environment and population estimates. The South Halton study area (refer to map) includes the urban areas of Burlington, Oakville and Milton as well as the Halton Hills 401 Corridor.

### PROCESS

This study has been undertaken in accordance with the requirements for master plans under Section 4, Approach #2 of the Municipal Class Environmental Assessment (EA) document (October 2000 as amended in 2007) which is approved under the Ontario Environmental Assessment Act, and will satisfy Phase 1 and 2 of the planning process. The Master Plan Update was presented at a Public Information Centre (PIC) held on September 19, 2007.

The Class EA Study Report for the Water and Wastewater Master Plan Update recommends the preferred water and wastewater servicing strategies and identifies the list of projects.

This Notice of Completion is issued with respect to all of the following Schedule A, A+ and B Master Plan projects.

### PUBLIC COMMENT INVITED

A Class EA Study Report for the Master Plan Update which documents the planning process undertaken and conclusions reached will be on public record for a minimum of 45 calendar days in accordance with the Municipal Class EA Document. **The Public "Review Period" will begin on Friday June 13, 2008 and end on Monday July 28, 2008.**

The Class EA Report for the Master Plan Update is available for public review at the following locations:

<b>Town of Oakville</b> , 1225 Trafalgar Road, Clerk's Department M-F 8:30am – 4:30pm	<b>Oakville Central Library</b> , 120 Navy Street M-Th 9:30am-9:00pm F-Sa 9:30am-5:00pm Su 1:00pm-5:00pm
<b>City of Burlington</b> , 426 Brant Street, Clerk's Department M-F 8:45am – 4:30pm	<b>Burlington Tansley Woods Library</b> , 1996 Itabashi Way M-Th 9:00am-9:00pm, F 9:00am-6:00pm, Sa 9:00am-5:00pm Su closed
<b>Town of Milton</b> , 555 Industrial Drive, Engineering Services Department M-F 8:30am – 4:30pm	<b>Milton Public Library</b> , 45 Bruce Street T-Th 10:00am-9:00pm F-Sa 10:00am-5:00pm Su-M closed
<b>Town of Halton Hills</b> , 1 Halton Hills Drive, Georgetown, Clerk's Department M-F 8:30am – 4:30pm	<b>Halton Hills Public Library</b> , Georgetown Branch, 9 Church Street Tu-Th 9:30am-8:30pm F-Sa 9:30am -5:00pm Su-M closed
<b>Region of Halton</b> , 1151 Bronte Road, Citizen's Reference Library M-F 8:30am – 4:30pm	

Also available electronically at: [www.halton.ca/SouthHaltonMasterPlan](http://www.halton.ca/SouthHaltonMasterPlan).

Subject to comments received as a result of this notice, Halton Region intends to proceed with the implementation of the recommended Schedule A, A+ and B projects included in the Class EA Master Plan Study Report. If after reading the Class EA Master Plan, you have any questions or concerns, please follow the subsequent procedure:

Contact the following Region staff to discuss your questions or concerns:

#### Lisa De Angelis

Senior Project Manager- Infrastructure Planning

Halton Region

1151 Bronte Road


Oakville, Ontario L6M 3L1

Tel: 905-825-6000 ext. 7547

Fax: 905-825-8822 E-mail: [lisa.deangelis@halton.ca](mailto:lisa.deangelis@halton.ca)

### SCHEDULE A – PRE-APPROVED ACTIVITIES

<b>Halton Hills</b>	
5879	300 mm WM Employment Servicing Loop on Steeles Ave near Ninth Line
5880	300 mm WM Employment Servicing Loop on Steeles Ave west of Trafalgar Rd
5949	300 mm WM Employment Loop on Steeles Ave east of Ninth Line
<b>Milton</b>	
5870	400 mm WM on new Milton South road from Britannia Rd to Louis St Laurent Ave
5873	400 mm WM on Main St from approx. Nipissing Rd to approx. Wilson Dr
<b>Oakville</b>	
3820	Install additional 75 MLD water pump capacity at Zone 3 C.B. Kitchen Pumping Station at Upper Middle Rd & Bronte Rd
3836	Install additional water pump capacity at Zone 5 C.B. Kitchen Pumping Station at Upper Middle Rd & Bronte Rd (30 MLD)



Arrange a meeting with the Project Manager (opposite) if you have significant concerns that may require more detailed explanation

If major concerns are raised, the Region will attempt to negotiate a resolution of the issues. A mutually acceptable time period for this negotiation will be set. If the issues remain unresolved, you have the option to request the Minister of the Environment, by order, to require the Region to comply with Part II of the Environmental Assessment Act before proceeding with a **Schedule B** project. This is called a Part II Order ("bump up"). Part II Orders cannot be submitted in respect of the Master Plan itself, but must be made in respect of one or more **Schedule B** projects listed in this Notice. The Minister may make one of the following decisions:

- Deny the request
- Refer the matter to mediation
- Require the Region to comply with Part II of the Environmental Assessment Act by undertaking one of the following:
  - Submitting the Class EA Master Plan for government review and approval
  - Completing an Individual Environmental Assessment for government review and approval
  - Preparing Terms of Reference governing the preparation of an individual Environmental Assessment.

Requests for a Part II Order must be submitted, in writing, to the Minister of the Environment within the **June 13, 2008 to July 28, 2008** review period:

#### Minister of Environment

Environmental Assessment and Approvals Branch  
135 St. Clair Avenue West, 12<sup>th</sup> Floor  
Toronto, ON M4V 1P5

A copy of the Part II Order must also be sent to Halton Region, to the attention of the Project Manager (address opposite).

Information will be collected in accordance with the **Freedom of Information and Protection of Privacy Act**. With the exception of personal information, all comments will become part of the public record.

This notice issued June 13 and 20, 2008.

### SCHEDULE A+ – PRE-APPROVED ACTIVITIES REQUIRING NOTIFICATION

<b>Burlington</b>	
5850	750 mm WM on Upper Middle Rd from Burloak Dr west to Appleby Line
3698	Waterdown Road water Pumping Station Expansion at Waterdown Road Reservoir
3787	750 mm WM crossing of QEW on Burloak Dr (500m) (already approved)
5319	600mm WM on Appleby Line from existing 600 mm (A-W14) approximately from Harrison Ct to Dundas St (Zone 3) - 200m
5534	600 mm WM on Appleby Line from existing 600 mm WM (A-W14) to Appleby Line Reservoir - 400m
5934	750 mm WM from Burloak WBS (Zone 2) north on Burloak Dr to Upper Middle Rd (not including QEW crossing)
5901	750 mm WWFM from Elizabeth Gardens WWPS east to Burloak Dr north to New St, west to Appleby Line, north to existing trunk
<b>Halton Hills</b>	
3844	600 mm WM on Steeles Ave from Trafalgar Rd to Ninth Line South
5948	600 mm WM on Steeles Ave from Ninth Line South to Winston Churchill Blvd
5903	2 x 300 mm WWF main from new WWPS at Eighth Line to just west of Trafalgar Rd on Steeles Ave
3863	600 mm WWM on Steeles Ave from Ninth Line to new WWPS at Eighth Line
4648	600 mm WWM on Steeles Ave from Winston Churchill Blvd to Ninth Line
5904	600 mm WWM from just west of Trafalgar to new WWPS Eighth Line on Steeles Ave