

SOUTH HALTON WATER AND WASTEWATER MASTER PLAN UPDATE CLASS ENVIRONMENTAL ASSESSMENT STUDY NOTICE OF COMPLETION - end

PROCESS

This study has been undertaken in accordance with the requirements for master plans under Section 4, Approach #2 of the Municipal Class Environmental Assessment (EA) document (October 2000 as amended in 2007) which is approved under the Ontario Environmental Assessment Act, and will satisfy Phase 1 and 2 of the planning process. The Master Plan Update was presented at a Public Information Centre (PIC) held on September 19, 2007.

The Class EA Study Report for the Water and Wastewater Master Plan Update recommends the preferred water and wastewater servicing strategies and identifies the list of projects.

This Notice of Completion is issued with respect to all of the following Schedule A, A+ and B Master Plan projects.

WM=Watermain WBS=Water Booster Station WPP=Water Purification Plant
WWM=Wastewatermain WWFM=Wastewater Forcemain
WWPS=Wastewater Pumping Station WWTP=Wastewater Treatment Plant
MLD=mega litres per day ML=mega litres mm=millimetres m=meters

SCHEDULE B – ACTIVITIES SUBJECT TO THE SCREENING PROCESS

Burlington	
54	New Zone 3 WBS at existing Appleby Line Reservoir
3699	North Aldershot - Reservoir
3700	400 mm WM from Waterdown Reservoir pumping station to new North Aldershot Reservoir
5881	400 mm WM from Waterdown pumping station (reservoir) down Waterdown Road along North Service Rd to King Rd (Zone 2 main)
5907	300 mm WWM North Aldershot Servicing on North Service Rd and Waterdown Rd
Halton Hills	
3838/ 3837	Watermain from James Snow Pkwy and 3rd Line to Zone 5 Lake Based Water Reservoir (20 ML) at 3rd Line between No. 10 and No.15 Sideroads. (WM and Reservoir) (under separate Class EA Study)
3864	New WWPS on Steeles Ave west of Winston Churchill Blvd
3865	2 x 200 mm WWFM for Halton Hills 401 Corridor from Ninth Line from new WWPS at Winston Churchill Blvd on Steeles Avenue
5061	New 30 ML Zone 4 Reservoir on Trafalgar Rd south of 5 Sideroad/Campbellville Rd
5902	New WWPS on Steeles Ave east of Eighth Line
Milton	
4980	New 30 MLD Zone 4/5 WBS at Fourth Line and Louis St. Laurent Ave
5064	2 x 250 mm WWFM from new WWPS at Fifth Line between Derry Road and Britannia Road westward to midway to Fourth Line
5525	600 mm WM north on re-aligned Tremaine Rd (Zone 5 main) from Main St to existing Zone 5 loop north of 401
5866	400 mm WM on Tremaine Rd from Derry Rd to Main St
5867	750 mm WM on Britannia Rd from Fourth Line to approximately 2350 m west (to new Milton South road)
5872	600 mm WM on Main St from Tremaine Rd to existing Zone 5 WM approximately 1200 m east
5875	900 mm WM on Derry Rd from Trafalgar Rd westward to new Milton road
5876	600 mm WM on new internal Milton road from Britannia Rd to Louis St Laurent Ave
5068	2 x 400 mm WWFM from new WWPS west of Third Line on Britannia to Regional Road 25
5899	2 x 200 mm WWFM from new WWPS south of Derry Road on Sixth Line to Fifth Line
5065	New WWPS on Fifth Line approximately 1200 m north of Britannia Rd West
5069	New WWPS on Britannia Rd approximately 300 m west of Third Line
5895	New WWPS at Fifth Line / Derry Rd W
5898	New WWPS on Sixth Line approximately 750 m south of Derry Rd W
5924	Reconstruction and Expansion of Fulton WWPS at the Milton WWTP

Full list also available electronically at: www.halton.ca/SouthHaltonMasterPlan.

SCHEDULE B – ACTIVITIES SUBJECT TO THE SCREENING PROCESS

Oakville	
81	New 40 MLD Zone 2 WBS at Third Line and North Service Rd
64	50 MLD Burloak WBS (Zone 2) on Burloak Dr north of Railway and south of Weycroft Road
3817	New 100 MLD Zone 3/4 WBS at Northpark – Neyagawa Blvd north of Dundas St (already approved)
82	750 mm WM on Third Line from Speers Rd to new Zone 2 WBS at Third Line/North Service Rd
3786	1500 mm WM from Burloak WTP on Rebecca St and northward on Burloak Dr to new Burloak WBS (Zone 2) north of railway
4975	1500 mm WM on Rebecca St from Burloak WPP to Bronte Rd
5321	1200 mm WM on Dundas St from Proudfoot Trail to Neyagawa Blvd (under the 16 Mile Creek) (already approved)
5528	500 mm WM on Rebecca St between Water St and Forsythe St (reconstruction hung from bridge over the Sixteen Mile Creek)
5855	750 mm WM (Zone 3 main) on Dundas St from Sixth Line to Neyagawa Blvd
5856	1200 mm WM (Zone 4 main) on Neyagawa Blvd from new WBS on Northpark to Burnhamthorpe Rd (already approved)
5878	400 mm WM on North Service Rd from Third Line to Bronte Rd
5926	1200 mm WM from Zone 3 C.B. Kitchen WBS to Bronte Rd, north on Bronte Rd to connect with existing 1200 mm WM at Bronte Rd/ West Oak Trail
3797	750 mm WWFM from new WWPS at Northpark along Dundas St and hung from the Bridge (over 16 Mile Creek) to just west of the bridge (old Fourth Line)
5893	2nd 750 mm WWFM from new WWPS at Northpark along Dundas St and hung from the Bridge (over 16 Mile Creek) to just west of the bridge (old Fourth Line)
5910	300 mm WWFM from Upper Middle Rd/Ninth Line under the QEW to new gravity sewer south on Ford Dr
5923	2x750 mm WWFM east of the Bridge from Neyagawa Blvd to WWPS on North Park Property
4671	2400 mm WWM on Upper Middle Rd from Bronte Rd to Third Line
5911	375 mm WWM from WWFM on Ford Dr to existing trunk sewer south of Clearview North
3798	New WWPS on North Park Property – Neyagawa Blvd north of Dundas St
4995	New WWPS on Dundas St E approximately 550m west of Ninth Line
5734	Mid Halton North Wastewater Pumping Station Expansion at Mid Halton WWTP
5909	New WWPS on Upper Middle Rd at Ninth Line

SCHEDULE C – ACTIVITIES SUBJECT TO ADDITIONAL STUDY THROUGH PHASES 3 & 4 OF THE MUNICIPAL CLASS EA PROCESS AND ARE NOT SUBJECT TO THIS NOTICE OF COMPLETION

NOTIFICATION WILL BE ISSUED WHEN THESE PROJECTS PROCEED TO PHASE 3 & 4 OF THE MUNICIPAL CLASS EA STUDY PROCESS.

Burlington	
5315	Skyway WWTP Expansion to 140 MLD
Burlington / Oakville	
3812	900 mm WM on Dundas from Appleby Line to Tremaine Rd
Milton / Oakville	
3794	2400 mm WWM from Regional Rd 25 at Lower Base Line across existing private land, under Highway 407 through North Oakville HUSP area on new road alignment to Dundas St at Third Line
3867	2100 mm WWM on Regional Rd 25 from Boyne WWPS to Lower Base Line
Oakville	
4976	1350 mm WM from Burloak WBS on Burloak Drive to C.B. Kitchen Reservoir at Upper Middle Road/Regional Road 25
3824	Burloak WPP Phase 2 Expansion to 110 MLD
5951	Burloak WPP Phase 3 Expansion to 165 MLD
3808	Mid-Halton WWTP Phase 4 expansion to 100 MLD
5945	Mid-Halton WWTP Outfall/Equalization Upgrade
5952	Mid-Halton WWTP Phase 5 expansion to 125 MLD